

Fall Protection Inspection Checklist

Anchorage Points

Type of Anchorage Point: _____ Manufacture Date: _____

Serial Number: _____ Lot Number: _____ Purchase Date: _____

Comments: _____

GENERAL FACTORS	ACCEPTED/ REJECTED	SUPPORTIVE DETAILS OR COMMENTS
1. Physical Damage: Inspect for cracks, sharp edges, burrs, and deformities	☐ ACCEPTED ☐ REJECTED	
2. Excessive Corrosion: Inspect for corrosion, which affects the operation and/or strength	☐ ACCEPTED ☐ REJECTED	
3. Fasteners: Inspect for corrosion, tightness, damage, and distortion. If welded, inspect weld for corrosion, cracks, and damage	☐ ACCEPTED ☐ REJECTED	
4. Markings: Inspect, make sure markings are legible	☐ ACCEPTED ☐ REJECTED	
5. Horizontal Lifeline: Minimum ½" steel wire, less than 30 feet between posts and less than 15" sag in a 30 feet span	☐ ACCEPTED ☐ REJECTED	
6. Vertical Lifeline: Minimum ½" steel wire or 5/8" polypropylene rope. Lifeline column adequately secured with rope grab that extends from the top to the base	☐ ACCEPTED ☐ REJECTED	

Overall Disposition	☐ ACCEPTED ☐ REJECTED	INSPECTED BY: _____ DATE INSPECTED: _____
---------------------	--	--